



December 16, 2024

ADDENDUM NO. 3

PROJECT 4077, 2024/25 CDBG ADA Curb Ramp Installation Project

NOTICE TO BIDDERS:

The following clarifications, amendments, additions and/or deletions as set forth herein shall apply to the above project contract documents and shall be made a part thereof and shall be subject to all the requirements thereof as though originally specified and/or shown. Submitters shall assure themselves that all addendum changes have been incorporated into their proposal.

A. ADDITIONS/DELETIONS

1. **None**

B. CLARIFICATIONS/QUESTIONS


Please be advised of the following clarifications to the contract documents:

1. Question – Will there be a separate bid item for asphalt patch back?
Answer – No, asphalt patch back / asphalt plug is incidental to bid item #8, Curb and Gutter.
2. Question – Is there re striping on this project?
Answer – No. There will be no re striping work done on this Project.
3. Question – What is the assumed depth of the HMA patch back?
Answer – Assume a 3" depth of HMA patch back / asphalt plug.

BIDDERS MUST SIGN AND ATTACH one (1) copy of this addendum document to the proposal as acknowledgment of receipt of these instructions and that said addendum was properly evaluated in the proposal.

ANY PROPOSAL NOT IN COMPLIANCE WITH THIS ADDENDUM MAY BE REJECTED.

Issued: 12/16/24


Senior Engineer

ADDENDUM NO. 3, PROJECT 4077, 2024/25 CDBG ADA Curb Ramp Installation Project is hereby acknowledged and was considered in this Project Proposal.

Bidder's Signature

Date

Firm Name

Mailing Address

City/State/Zip+4